

Purchase Order No.
1503385P
Work Order No.

FORM R-1 REPORT OF REPAIR

in accordance with the provisions of the *National Board Inspection Code*

1. Work performed by **Mechanical Technologies, Inc.** (name of repair organization) 52
(Form Registration No.)
701 Morley Road, Green Bay, Wisconsin, 54303 (address) 1502356P
(Po No., Job No., etc.)

2. Owner **ST. Paper LLC** (name)
106 E CENTRAL AVE, Oconto Falls, Wisconsin, 54154 (address)

3. Location of installation **ST. Paper LLC** (name)
106 E CENTRAL AVE, Oconto Falls, Wisconsin, 54154 (address)

4. Item identification **Boiler** (boiler, pressure vessel or piping) Name of original manufacturer **Hurst Boiler and Welding**

5. Identifying nos.: **HYB9750-200-1** (mfg. serial no.) **14245** (National Board No.) **B0088276** (Jurisdiction No.) **N/A** (other) **2008** (year built)

6. NBIC Edition / Addenda: **2007** (edition) **N/A** (addenda)

Original Code of Construction for Item: **ASME section 1** (name/ section/ division) **2007/** (edition/ addenda)

Construction Code Used for Repair Performed: **ASME section 1** (name/ section/ division) **2013/** (edition/ addenda)

7. Repair Type: Welded Graphite Pressure Equipment FRP Pressure Equipment

8. Description of work: Form R4 Supplemental Sheet is attached FFSA Form (NB-403) is attached
Replace 1 - 3" SA178 .105 wall tube in the 3rd pass by mechanically expand and bead tube ends into tube sheet. Plug 2 - 3" tubes in the 2nd pass by installing plugs on each end and seal weld plug to tube.


Hydrostic Pressure Test, if applied **190 psi** **MAWP** **200 psi**

9. Replacement Parts. Attached are Manufacturer's Partial Data Reports or Form R-3s properly completed for the following items of this report:
N/A
(name of part, item number, data report type or Certificate of Compliance, mfg. name, and identifying stamp)

10. Remarks: **** REPAIR OF ROUTINE NATURE--DOES NOT REQUIRE INSPECTION BY AUTHORIZED INSPECTOR ****

CERTIFICATE OF COMPLIANCE


I, **Thomas Arnoldi**, certify that to the best of my knowledge and belief the statements in this report are correct and that all material, construction, and workmanship on this Repair conforms to the *National Board Inspection Code*.
National Board "R" Certificate of Authorization No. **6276** expires on **May 21, 2015**

Date **03/19/2015**, **Mechanical Technologies, Inc.** (name of repair organization) Signed  (authorized representative)

CERTIFICATE OF INSPECTION

I, **Mark F. VanCampenhou**, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency, where required, issued by the Jurisdiction of **WI, MI** and employed by **HSB Global Standards** of **Hartford, CT** have inspected the work described in this report on **April 1, 2015** and state that to the best of my knowledge and belief this work complies with the applicable requirements of the *National Board Inspection Code*.

By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection.

Date **April 1, 2015** Signed  (inspector) Commissions **13264, WI1048636, MI300540** (National Board and Jurisdiction No.)

**FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS
EXCEPT WATERTUBE AND ELECTRIC**

As Required by the Provisions of the ASME Code Rules, Section I

500 P.P.

Manufactured by Hurst Boiler and Welding Company Inc. 21971 US HWY. 319 N., COOLIDGE, GA. 31738
(Name and address of Manufacturer)

Manufactured for SPIRIT CONSTRUCTION SERVICES, INC.; 3131 MARKET STREET; GREEN BAY, WI. 54304
(Name and address of purchaser)

Location of installation ST PAPER - OCONTO FALLS TISSUE; 106 E. CENTRAL AVE.; OCONTO FALLS, WI. 54154
(Name and address)

Type: HYBRID Boiler No. HYB9750-200-1 NA 0700142 14,245 Year Built 2008
(HRT, etc.) (Mfr's. Serial No.) (CRN) (Drawing No.) (Nat'l. Board No.)

The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to Section I of the ASME Boiler and Pressure Vessel Code 2007
(year)

Addenda to NONE, and Code Cases NONE
(Date) (Numbers)

Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors are attached for the following items of this report:
NONE
(Name of part, item number, mfr's name and identifying stamp)

Shells or drums: 1 SA-516-70 3/4" 120" 268.25" NA NA
(no.) (mat'l. spec., gr.) [thickness (in.))] [dia. (ID)] (length, inside) [dia. (ID)] (length, inside)

Joints: WELDED 100% WELDED 3
[long. (seamless, welded)] [efficiency (as compared to seamless)] [girth (seamless, welded)] (no. of shell courses)

Heads: SA-516-70 7/8" THK. FLAT NA
(Material Specification No.: Thickness - Flat, Dished, Ellipsoidal - Radius of Dish)

Sheet: SA-516-70 7/8" THK. Tube Holes: 3"
(Mat'l. Spec., Grade, Thickness) (Dia)

Tubes: No. (546) SA-178-A STRAIGHT
(Mat'l. Spec., Grade) (Straight or Bent)

Dia 3" Length 272-1/2" Gauge 12
(if various, give max & min) (or thickness)

Furnace No. NA Size NA Length, each section NA Total NA
(O.D. or W x H)

Type NA
(Plain, Adamson, Ring Reinforced, Corrugated, Combined, or Stayed)

Seams: Type NA
(Mat'l. Spec., Grade, Thickness) (Seamless, Welded)

Staybolts: No. 32 Size 2" SA-675-70 100.54" SQ.
(Dia. Mat'l., Spec., Grade, Size Telltale, Net Area)

Pitch 12.75" MAWP 200 psi.
(Hor. and Vert.)

Stays or braces:

Location	Material Spec. No.	Type	No. & Size	Max. Pitch	Fig. PFT-32 L/I	Dist. Tubes to Shell	MAWP, psi.
(a) F.H. above tubes	SA-675-70	DIAG.	(16) 2"	12.75"	13	46"	200
(b) R.H. above tubes	SA-675-70	DIAG.	(16) 2"	12.75"	13	46"	200
(c) F.H. below tubes	NA						
(d) R.H. below tubes	NA						
(e) Through stays	NA						
(f) Dome braces	NA						

Other parts 1. MEMBRANE TUBES 2. MEMBRANE HEADERS 3. MEMBRANE HEADERS
(Brief Description - i.e., Dome, Boiler Piping, etc.)

- (124) 2-1/2" X .105", SA-178-A BENT BOILER TUBES, 12 GAUGE, 200 P.S.I.
 - (3) 10" SCH 40, SA-106-B PIPES, T. & B. MEMBRANE HEADERS, - (2) 10" STD. WELD TEE'S, SA234 GR WPB, 200 P.S.I.
 - (3) 10" 300# R.F., BLIND FLGS., SA-105 - (3) 10" 300# R.F., W.N. FLGS., SA-105, 200 P.S.I.
- (Mat'l. Spec. Grade Size Material Thickness. MAWP)

**FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS
EXCEPT WATERTUBE AND ELECTRIC**

500 H.P.

As Required by the Provisions of the ASME Code Rules, Section I

Manufactured by Hurst Boiler and Welding Company Inc. 21971 US HWY. 319 N., COOLIDGE, GA. 31738
(Name and address of Manufacturer)

Manufactured for SPIRIT CONSTRUCTION SERVICES, INC.; 3131 MARKET STREET; GREEN BAY, WI. 54304
(Name and address of purchaser)

Location of installation ST PAPER - OCONTO FALLS TISSUE; 106 E. CENTRAL AVE.; OCONTO FALLS, WI. 54154
(Name and address)

Type: HYBRID Boiler No. HYB9750-200-1 NA 0700142 14,245 Year Built 2008
(HRT, etc.) (Mfr's. Serial No.) (CRN) (Drawing No.) (Nat'l. Board No.)

The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to Section I of the ASME Boiler and Pressure Vessel Code 2007
(year)

Addenda to NONE, and Code Cases NONE
(Date) (Numbers)

Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors are attached for the following items of this report:

NONE
(Name of part, item number, mfr's name and identifying stamp)

Shells or drums: 1 SA-516-70 3/4" 120" 268.25" NA NA
(no.) (mat'l. spec., gr.) [thickness (in.)] [dia. (ID)] (length, inside) [dia. (ID)] (length, inside)

Joints: WELDED 100% WELDED 3
[long. (seamless, welded)] [efficiency (as compared to seamless)] [girth (seamless, welded)] (no. of shell courses)

Heads: SA-516-70 7/8" THK. FLAT NA
(Material Specification No.: Thickness - Flat, Dished, Ellipsoidal - Radius of Dish)

Cover sheet: SA-516-70 7/8" THK. Tube Holes: 3"
(Mat'l. Spec., Grade, Thickness) (Dia)

Tubes: No. (546) SA-178-A STRAIGHT
(Mat'l. Spec., Grade) (Straight or Bent)

Dia 3" Length 272-1/2" Gauge 12
(if various, give max & min) (or thickness)

Furnace No. NA Size NA Length, each section NA Total NA
(O.D. or W x H)

Type NA
(Plain, Adamson, Ring Reinforced, Corrugated, Combined, or Stayed)

Seams: Type NA
(Mat'l. Spec., Grade, Thickness) (Seamless, Welded)

Staybolts: No. 32 Size 2" SA-675-70 100.54" SQ.
(Dia. Mat'l., Spec., Grade, Size Telltale, Net Area)

Pitch 12.75" MAWP 200 psi.
(Hor. and Vert.)

Stays or braces:

Location	Material Spec. No.	Type	No. & Size	Max. Pitch	Fig. PFT-32 L/I	Dist. Tubes to Shell	MAWP, psi.
(a) F.H. above tubes	SA-675-70	DIAG.	(16) 2"	12.75"	13	46"	200
(b) R.H. above tubes	SA-675-70	DIAG.	(16) 2"	12.75"	13	46"	200
(c) F.H. below tubes	NA						
(d) R.H. below tubes	NA						
(e) Through stays	NA						
(f) Dome braces	NA						

Other parts 1. MEMBRANE TUBES 2. MEMBRANE HEADERS 3. MEMBRANE HEADERS
(Brief Description - i.e., Dome, Boiler Piping, etc.)

- (124) 2-1/2" X .105", SA-178-A BENT BOILER TUBES, 12 GAUGE, 200 P.S.I.
- (3) 10" SCH 40, SA-106-B PIPES, T. & B. MEMBRANE HEADERS, - (2) 10" STD. WELD TEE'S, SA234 GR WPB, 200 P.S.I.
- (3) 10" 300# R.F., BLIND FLGS., SA-105 - (3) 10" 300# R.F., W.N. FLGS., SA-105, 200 P.S.I.
(Mat'l. Spec., Grade, Size, Material Thickness, MAWP)

ALM 4-1-15

H.V.A.C.
SYSTEMS
SERVICE INC.

Procedure Qualification Record No.: 311-SM-O-E60/70 PQR Date 4/10/98

Supporting WPS No.(s) 311-SM-O-E60/70


Welding Processes Shielded Metal Arc Welding (SMAW)

Type (Manual, Automatic, Semi-auto) Manual

Joints (QW-402)

Actual Deposit Thickness of Each Filler & Process used Must Be Recorded;

Process	Thickness
(F-No. 3)	0.125"
(F-No. 4)	0.250"



Base Metals (QW-403)

Material: SA 106 to SA 106
 Type or Grade GR B to GR B
 P-No. 1 Group-No. to P-No. 1 Group-No.
 Thickness of Test Coupon 0.375" (machined)
 Diameter of Test Coupon 2" NPS
 Other

Post Weld Heat Treatment (QW-407)

Temperature None performed
 Time
 Other

Gas (QW-408)	Gas(es)	Mixture	Flow Rate
Shielding	<u>N/A</u>	<u> </u>	<u> </u> CFH
Backing	<u>N/A</u>	<u> </u>	<u> </u> CFH
Trailing	<u>N/A</u>	<u> </u>	<u> </u> CFH

Filler Metals (QW-404)

SFA Spec. SMAW, 5.1
 AWS Class E6010 & E7018
 Filler Metal F-No. E6010, F-No.3 E7018, F-No. 4
 Weld Metal Analysis A-No.: 1
 Size of Filler Metal
 (F-No. 3) 1/8" (F-No. 4) 3/32"

Electrical Characteristics (QW-409)

	(F-No. 3)	(F-No. 4)
Current	<u>Direct (DC)</u>	<u>Direct (DC)</u>
Polarity	<u>Reverse</u>	<u>Reverse</u>
Amps	<u>75</u>	<u>97 - 105</u>
Volts	<u>not recorded</u>	<u>not recorded</u>
Tungsten Electrode Type & Size	<u>N/A</u>	
Orifice Size	<u> </u>	

Position (QW-405)

Position of Groove 6G
 Weld Progression (uphill, downhill) Uphill
 Other

Technique (QW-410)

	Travel Speed - IPM	String/Weave
(F-No. 3)	<u>not recorded</u>	<u>String</u>
(F-No. 4)	<u>not recorded</u>	<u>String</u>

Preheat (QW-406)

Preheat Temperature 65° F (ambient)
 Interpass Temperature Not recorded
 Other

Single or Multipass (per side) Multipass
 Single or Multiple Electrodes Single
 Other

APR 11 2013

CERTIFIED MILL TEST REPORT

TEKTube
 4150 South Elwood
 Tulsa OK 74107
 Phone: 918 446-4561
 FAX:

MTR No: 20131634
 MTR Date: 11/8/2013
 Sales Order No: 20131634
 Customer PO No: CB0762

CUSTOMER
 Chicago Tube & Iron

TUBE: Tube 3.00 OD x .105 MW
 ASME SA-178-A ERW 2010 EDITION, 2011 ADDENDA
 ALUMINUM KILLED STEEL

HEAT NO.	C.	Mn.	P.	S.	SI.	Al.	Cu.	HRB.	Yield	Tensile	Elong.
235932	JA1386	0.070	0.47	0.007	0.001	0.030	0.040	.130	58 / 59		
236545	JA1309	0.070	0.47	0.006	0.001	0.030	0.030	.140	59 / 60		
236546	JA1323, JA1351 JA1379, JA1386 JA1400	0.070	0.49	0.007	0.001	0.030	0.030	.140	58 / 59		

TESTING
 FLANGE, FLATTENING, FLARE, REVERSE FLATTENING, U.T. TEST ON WELD AREA
 PER E273 AND ASME, 100% FULL PERIPHERY (ENCIRCLING COIL) EDDY CURRENT TEST
 IN ACCORDANCE WITH ASME SA-450 AND SE-309, 2010 EDITION, 2011 ADDENDA
 USING 0.024" DIAMETER DRILLED HOLE (-.000 / + .002) ARE SATISFACTORY.

COMMENTS: TAG INFO: JA1323; JA1351; JA1379; JA1386; JA1400; JA1304 |

We certify that each lot has been manufactured, sampled, tested, and inspected in accordance with above specifications and meets all of the specification requirements. Tubes manufactured in USA.

Signature:  Date: 11/8/2013



US-ML-ST PAUL
1678 RED ROCK ROAD
SAINT PAUL, MN 55119
USA

CUSTOMER SHIP TO
CUSTOMER BILL TO

GRADE
A55

SHAPE / SIZE
Round Bar / 2"

HEAT / BATCH
62132168704

WEIGHT
3.460 LB

LENGTH
20'00"

SALES ORDER
525556/000010

CUSTOMER MATERIAL N°
HR200

CUSTOMER PURCHASE ORDER NUMBER
01454749

BILL OF LADING
1332-000007008

DATE
08/27/2013

SPECIFICATION / DATE of REVISION
1-ASTM A569M-11
2-A36/36M-08
3-ASTM A569M-11
4-ASME SAJ0-08A

CHEMICAL COMPOSITION

C %	0.16	Mn %	0.71	P %	0.008	S %	0.027	Si %	0.23	Cu %	0.29	Ni %	0.17	Cr %	0.12	Mo %	0.038	V %	0.002	Nb %	0.000	Sn %	0.011
-----	------	------	------	-----	-------	-----	-------	------	------	------	------	------	------	------	------	------	-------	-----	-------	------	-------	------	-------

MECHANICAL PROPERTIES

Elong %	26.90	UTS KSI	67500
	26.20	UTS MPa	67200

MECHANICAL PROPERTIES

YS KSI	44.9	UTS KSI	67.5
YS MPa	310	UTS MPa	67.2
	44.6		

GEOMETRIC CHARACTERISTICS

R/R 9/74

HARDENABILITY

D1 A255
Inch 0.57

COMMENTS / NOTES

Material 100% melted and rolled in the USA. Manufacturing processes for this steel, which may include scrap melted in an electric arc furnace and hot rolling, have been performed at Gerdaul St. Paul Mill, 1678 Red rock Rd. St. Paul, Minnesota, USA. All products produced from strand cast billets. Silicon killed (deoxidized) steel. No weld repairment performed. Steel not exposed to mercury or any liquid alloy which is liquid at ambient temperatures during processing or while in Gerdaul St. Paul Mill's possession. Any Modification to this certification as provided by Gerdaul # St. Paul Mill without the expressed written consent of Gerdaul St. Paul Mill negates the validity of this certification as report shall not be reproduced except in full, without the expressed written consent of Gerdaul St. Paul Mill. Gerdaul St. Paul Mill is not responsible for the usability of this material in any specific applications.
Roll batch 62132168704 roll dtd 8/20/2013

Inspected and Approved

ASB 28 003

Arthur 4-1-15

The above figures are certified chemical and physical test records as contained in the permanent records of company. This material, including the billets, was melted and manufactured in the USA. CMTR complies with EN 10204 3.1.

Shaskay
BHASKAR YALAMANCHILI
QUALITY DIRECTOR

M. B.
ALEX BRAMENBURG
QUALITY ASSURANCE MGR


MTi

701 Morley Road
Green Bay, WI 54303

WPS



REFERENCE ASME GENERAL WELDING PROCEDURE
WITH THIS SPECIFICATION

AE MUR 4-15

Welding Procedure Specification - ASME Sect. IX - QW-201.1 Supporting PQR No.(s) <u>31/10C-SM-O PQR</u>	WPS No. <u>31/10C-SM-O</u> Page 1 of 2
Welding Processes <u>Shielded Metal Arc Welding</u> Type <u>Manual</u>	Title: <u>Shielded Metal Arc Welding P-No. 1 to P-No. 10C Materials in Compliance With ASME B31.1, B31.3, ASME Section I and VIII, Div. 1</u>
Approved By:  Date <u>5/27/14</u>	

Joints (QW-402) See Engineering Drawings for additional Joint Designs

Joint Design; "V" Groove, Fillet and Socket Welds.
 Qualified without backing, backing with Same "P-No." material is optional.
 Root Spacing: "V" Groove, open butt, 1/16" to 3/16"
 Root Spacing: "V" Groove, with backing, 1/8" to 1/4"
 Maximum Mismatch: 1/16" (Groove joints)



Base Metals (QW-403)

P-No. 1 Group No. 1 & 2 to P-No. 10C Group No. 1

Thickness Range _____
 Base Material; _____

Groove <u>0.0625" to 0.750" Maximum</u>	Fillet <u>Unlimited</u>
Deposited Weld metal	
Groove <u>F-No. 3, 0.186" Maximum</u>	Fillet <u>0.500 Maximum Throat Thickness</u>
Groove <u>F-No. 4, 0.564" Maximum</u>	Fillet <u>0.500 Maximum Throat Thickness</u>
Groove <u>-----</u>	Fillet <u>-----</u>
Pipe Diameter Range <u>Unlimited</u>	Fillet <u>Unlimited</u>

Filler Metals (QW-404)

SFA Spec. 5.5 Filler Metal F-No. 3 (E8010-P1) and 4 (E8018-C3)

AWS Class E8010-P1* and/or E8018-C3** E8010-P1 A-No.: N/A
 E8018-C3 A-No.: 10

* E8010-G may be substituted for E8010-P1.
 ** E8018-C1 may be substituted for E8018-C3.

Size of Filler Metals See Table on page 2 of 2

Position (QW-405)

Position of Groove All

Weld Progression (uphill, downhill) Uphill

Other _____

Preheat (QW-406) See page 2 of 2 for additional notes

Material Thickness	Minimum Temperature (°F)	Maximum Interpass Temperature (°F)
<u>≤0.500"</u>	<u>50 ° F *</u>	<u>650 ° F</u>
<u>>0.500" **</u>	<u>175° F</u>	<u>650 ° F</u>

Post Weld Heat Treatment (QW-407)

Temperature None

Time _____

Other _____

Preheat Maintenance
 Continuous to completion of the weld.
 * Preheat of 175° F required for NBIC repair welds.
 ** Preheat required for all base materials over 1/2".

Gas (QW-408)	Gas(es)	Mixture	Flow Rate
Shielding	N/A		
Backing	N/A		
Trailing	N/A		

Electrical Characteristics (QW-409)	
Tungsten Electrode Size and Type	N/A
Mode of Transfer for GMAW	N/A
Wire Speed Feed Range	N/A

Weld Layer No.	Welding Process	Filler Metal *		Type Polarity	Current Range		Recommended Travel Speed - IPM
		Class	Diameter		Amp Range	Volt Range	
Open butt root**	SMAW	E8010-P1	0.093"	DC-Reverse	45 - 90	21 - 26	1" Minimum
		E8010-P1	0.125"	DC-Reverse	70 - 125	23 - 28	1.5" Minimum
Fill	SMAW	E8018-C3	0.093"	DC-Reverse	70 - 110	21 - 25	1" Minimum
		E8018-C3	0.125"	DC-Reverse	100 - 150	21 - 26	2" Minimum
		E8018-C3	0.156"	DC-Reverse	130 - 190	21 - 27	2.5" Minimum

* Alternate filler metal of same F-No may be used with above parameters. ** E8010-P1 may be omitted if backing is used.

Technique (QW-410)

Cleaning Prior to Welding - File or machine all scale / oxide to provide a clean bright surface for a min. of one inch from the anticipated toe of the weld. Complete cleaning with an approved solvent to assure complete removal of all harmful contaminants from both sides of the base metal. Precautions must be taken to prevent subsequent contamination of material surfaces. Incomplete cleaning can contribute to weld discontinuities.

Interpass Cleaning - Chip, file, grind or brush as required to remove all slag and discontinuities from the weld surface which would be detrimental to the satisfactory completion of the weld.

Arc Strikes - Arc Strikes outside of the area to be welded shall be avoided. Inadvertent arc strikes on the unwelded surfaces shall be repaired by blending to clean metal by mechanical means taking care to maintain thickness req'd.

Orifice size	N/A	Method of Backgouging;
Single or Multipass (per side)	Multipass	Required for joints welded two sides;
Single or Multiple Electrodes	Single	backgouge to sound metal by thermal
String/Weave	Root String, Remainder either stringer or weave.	or mechanical means and clean of all
		foreign material prior to welding the
		second side.
Deposit Thickness	No pass shall exceed 0.250" in thickness	
Contact Tube to Work Distance	N/A	Peening
		None permitted

- NOTES;**
- 1) E8010-P1 electrodes are limited to root passes when welding open butt joints.
 - 2) Filler metals may vary in size, and sequence used, to provide for physical configurations encountered.
 - 3) Preheat should be monitored by pyrometer, temperature indicating crayons or other approved means.
 - 4) Fillet welds to pressure parts require minimum of 175° F. preheat when thickness of the pressure part exceeds 3/4".

ATW 4-1-15



UA / NCPWB



Joint Welder Testing Program Welder Qualification Test Record

Welder's Name: Paul W Anderson SSN or UA card number: 398862668 Stamp No: PW 11
 Welder's Home Local: _____ Test Location: UA Local 434 Training City: Camp Douglas State: WI
 UA Test Assembly ID No: 02PWA2668

Testing Conditions and Ranges Qualified

Identification of WPS followed during welding of test coupon: UA-2, NCPWB (WPS 1-12-1)
 Specification of Test Coupon Base Metal: A/SA-106 Grade B or A/SA-53 Grade B Thickness(in.): 0.280

Welding Variables	Actual Values	Range Qualified
Welding Process(es) used:	<u>SMAW</u>	<u>SMAW</u>
Type of welding (manual, semi-automatic):	<u>Manual</u>	<u>Manual</u>
Base Metal P or S-Number <u>1</u> to P or S-number	<u>1</u>	<u>1 through 11</u>
<input type="checkbox"/> Plate <input checked="" type="checkbox"/> Pipe (enter diameter if pipe or tube):	<u>NPS 6, Sch 40 (0.280")</u>	<u>2-7/8 in. OD and over</u>
Backing (metal, weld metal, backwelded, etc):	<u>None / Weld metal</u>	<u>F-3 Opt., F-1, 2, 4 Req'd</u>
Filler Metal (SFA) Specification(s) (info. only):	<u>5.1</u>	
Filler Metal or Electrode Classification(s) (info. only):	<u>E6010 / E7018</u>	
Filler Metal or Electrode F-Number:	<u>3 / 4</u>	<u>1 through 4</u>
Solid, Metal Cored or Flux Cored wire for GTAW:	<u>N/A</u>	<u>N/A</u>
Consumable Insert for GTAW or PAW:	<u>N/A</u>	<u>N/A</u>
Deposit Thickness for each process and variation (in.):	<u>0.093 / 0.187</u>	<u>F-4, 0.374/F-1/3, 0.560max</u>
Position (2G, 6G, 3F, etc.):	<u>6G</u>	<u>All</u>
Progression (uphill, downhill):	<u>Uphill</u>	<u>Uphill</u>
Fuel Gas for OFW, Backing Gas for GTAW, PAW, GMAW:	<u>N/A</u>	<u>N/A</u>
GMAW Transfer Mode (short circuiting, spray, etc.):	<u>N/A</u>	<u>N/A</u>
GTAW Current Type/Polarity (AC, DCEP, DCEN):	<u>N/A</u>	<u>N/A</u>

* Indicates that at least 3 layers of weld metal were deposited

Testing and Results

Visual Examination of Completed Weld: Acceptable Date of Test: June 8 2011

Bend Test Transverse Root and Face (QW-462.3(a)) Side (QW-462.2)

Type	Result	Type	Result	Type	Result

Radiographic Examination Results: Acceptable Lab Test No.: _____
 Film or Specimens Evaluated By: Justin Ross Title: RT Tech Company: AET
 Contractor/Fabricator's Supervisor: Mike Rattle Title: Rep Company: Tweet Garot

We certify that the statements in this record are correct and that the test coupons were prepared, welded and tested in accordance with the requirements of Section IX of the ASME Code.

National Certified Pipe Welding Bureau Chapter Number: 5

United Association Authorized Testing Representative

Mike Rattle/Tweet Garot Contractor/Fabricator Name

Secretary: _____

Name: Ken Thompson

Signature: [Signature]

Date: June 8 2011

Date: June 8 2011


Date: June 8 2011

Mechanical Technologies, Inc.
 701 Morley Road
 Green Bay, WI 54303

**WELD PLAN
 WELD PROCESS TRAVELER**

JOB NO. 1502256P		INITIATED BY (PLANNER): Tom Arnoldi		DATE 3/15/2015	
NAME OF A.I. NOTIFIED / RELEASE Mark Vancampenhout		DATE 3/10/2015	TIME	<input type="checkbox"/> AM	BY
PRIORITY		SCHEDULE DATE	QC APPROVED		RELEASE DATE

EQUIPMENT DESCRIPTION Boiler		COMPONENT I.D.	MANUFACTURER Hurst Boiler	YEAR BUILT 2008
		MANUFACTURER'S SERIAL NUMBER HYB9750-200-1	NATIONAL BOARD NUMBER	
		MAWP 200 PSI AT °F	MDMT (IF APPLICABLE) °F at psi	



DESCRIPTION OF REPAIR
Remove & replace 1 - 3" tube in the 3rd pass. Plug - 2 - 3" tubes in the 2nd pass and sealweld plug in place

IDENTIFICATION OF MATERIAL TO BE WELDED

KEY	SPECIFICATION	GRADE / TYPE	P-NO.	THICKNESS
1-4	SAB		1	

WELD NO	WELD / REPAIR LOCATIONS (E.G. TUBE BANK & NUMBER)
WELD #1 - 4	Seal weld - 4 - 3" tapered plugs
WELD	
WELD #	

WPS NO. 311-SM-D-E60/70	PROCESS SMAW	FILLER METAL CLASSIFICATION	PREHEAT °F	INTERPASS °F
----------------------------	------------------------	-----------------------------	-------------------	---------------------

REPAIR WELDING AND INSPECTION OPERATIONS Check applicable instructions, use "N/A" if not applicable	Weld #1 - 4		Weld #		Weld #	
	QC	AI	QC	AI	QC	AI
<input type="checkbox"/> DEFECT EXCAVATION INSPECTION						
<input type="checkbox"/> PRE-WELD INSPECTION OF SURFACE CONDITION						
<input type="checkbox"/> FIT-UP AND ALIGNMENT CHECK						
<input type="checkbox"/> ROOT INSPECTION						
<input type="checkbox"/> INTERPASS INSPECTIONS						
<input checked="" type="checkbox"/> FINAL WELD VISUAL						
<input type="checkbox"/> FINAL WELD EXAMINATION						
WELDERS IDENTIFICATION NUMBER	PWA					
OTHER						

REPAIR COMPLETE AND CHECKED BY / DATE 3-15-15 <i>Tom Arnoldi</i>	AUTHORIZED INSPECTOR <i>Tom Arnoldi</i> 4-1-15
---	---

Mechanical Technologies, Inc.
701 Morley Road
Green Bay, WI 54303



REPORT OF PRESSURE TEST

ATM 4-1-15

JOB NUMBER 1502356P

PRIORITY

PREPARED BY / DATE
3/11/2015

COMPONENT I.D. AND DESCRIPTION:

MAWP: 200 psig @ °F

TEST BOUNDARY: Boiler

Refer To Drawing No.

TYPE OF TEST (and test parameters):

HYDROSTATIC

TEST MEDIUM:

TEMPERATURE (° F):

AMBIENT

PNEUMATIC

SOAP SOLUTION:

<input checked="" type="checkbox"/>	STATIC HEAD ALLOWANCE:	psig
	STATIC HEAD INSIGNIFICANT	

TEST PRESSURE:

psig

EXAMINATION PRESSURE:

psig

ASME SECTION I

ASME SECTION VIII, DIVISION 1

ASME B31.1

OTHER

SPECIAL INSTRUCTIONS / SPECIFICATIONS:

PRETEST CHECKLIST:

1. Modifications complete, including the isolation or removal of devices that will not withstand test pressure. N/A
2. Pressure test gauge installed and visible to operator: RANGE: 0 - 5000 psig
SERIAL NO: 7679001001 CALIBRATION DUE: 9/24/2015 N/A
3. Temperature instrument installed: SERIAL NO: _____ CALIBRATION DUE: _____ N/A
4. Pressure relief/regulating device installed: SETTING: _____ psig N/A
5. Drains and vents installed and used during filling operation. N/A
6. All boundary valves checked and closed (check valves installed in correct direction) N/A
7. All through valves checked and open. N/A
8. Test item thoroughly checked - no visible defects or damage. N/A

TEST CONDUCT:

TEST DATE: 3/11/2015 TEST PRESSURE AT GAUGE: 180 psig TEST PRESSURE _____ °F

HOLDING TIME: 10 min. PRESSURE AT GAUGE DURING EXAMINATION: 180 psig

TEST RESULTS (REMARKS)

ITEM/SYSTEM RESTORED TO OPERATING CONDITION/CONFIGURATION - VERIFIED BY: _____

DATE: _____

CONDUCTED BY: _____ QUALITY CONTROL APPROVED: _____

AUTHORIZED INSPECTOR ACCEPTANCE: _____

WITNESSED: _____ TITLE: _____ COMPANY: _____

WITNESSED: _____ TITLE: _____ COMPANY: _____

